

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Ground modular terminal block, Connection method: Push-in connection, Cross section: 25 mm<sup>2</sup> - 95 mm<sup>2</sup>, AWG: 4 - 3/0, Width: 25 mm, Color: green/yellow, Mounting type: 2.3 mm copper DIN rail

#### **Product Features**

- Quick and easy connection is now also possible for large conductors with the high-current terminal block
- The Push-in connection terminal blocks are characterized by the system features of the CLIPLINE complete system and by easy and tool-free wiring of conductors with ferrules or solid conductors
- In addition to using the existing test connection, pick-off terminal blocks can be connected, each of which can also accommodate two test cables
- Tested for railway applications



## Key commercial data

Packing unit	1 pc
Minimum order quantity	10 pc
Weight per Piece (excluding packing)	272.0 GRM
Custom tariff number	85369010
Country of origin	Poland

#### Technical data

#### General

Number of levels	1	
Number of connections	2	
Color	green/yellow	
Insulating material	PA	
Inflammability class according to UL 94	V0	
Area of application	Railway industry	
	Mechanical engineering	
	Plant engineering	



# Technical data

#### General

Maximum load current	232 A (with 95 mm² conductor cross section)
Rated surge voltage	8 kV
Pollution degree	3
Surge voltage category	III
Insulating material group	I
Connection in acc. with standard	IEC 60947-7-2
Maximum load current	232 A (with 95 mm² conductor cross section)
Nominal current I <sub>N</sub>	232 A
Maximum load current	232 A (with 95 mm <sup>2</sup> conductor cross section)
Open side panel	nein
Shock protection test specification	DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection	guaranteed
Finger protection	guaranteed
Test specification, oscillation, broadband noise	DIN EN 50155 (VDE 0115-200):2008-03
Test spectrum	Service life test category 2, bogie mounted
Test frequency	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$
ASD level	6.12 (m/s²)²/Hz
Acceleration	3.12 g
Test duration per axis	5 h
Test directions	X-, Y- and Z-axis
Oscillation, broadband noise test result	Test passed
Test specification, shock test	DIN EN 50155 (VDE 0115-200):2008-03
Shock form	Half-sine
Acceleration	30g
Shock duration	18 ms
Number of shocks per direction	3
Test directions	X-, Y- and Z-axis (pos. and neg.)
Shock test result	Test passed
Temperature index, insulating material (DIN EN 60216-1 (VDE 0304-21))	125 °C
Static insulating material application in cold	-60 °C

#### Dimensions

Width	25 mm
Length	105.5 mm
Height NS 35/15	108.7 mm

#### Connection data

Note	May only be mounted on 2.3 mm copper DIN rails



## Technical data

#### Connection data

Connection in acc. with standard	IEC 60947-7-2
Connection method	Push-in connection
Conductor cross section solid min.	25 mm²
Conductor cross section solid max.	95 mm²
Conductor cross section AWG/kcmil min.	4
Conductor cross section AWG/kcmil max	3/0
Conductor cross section stranded min.	25 mm²
Conductor cross section stranded max.	95 mm²
Min. AWG conductor cross section, stranded	4
Max. AWG conductor cross section, stranded	4/0
Conductor cross section stranded, with ferrule without plastic sleeve min.	25 mm <sup>2</sup>
Conductor cross section stranded, with ferrule without plastic sleeve max.	95 mm²
Conductor cross section stranded, with ferrule with plastic sleeve min.	25 mm <sup>2</sup>
Conductor cross section stranded, with ferrule with plastic sleeve max.	95 mm <sup>2</sup>
Cross section with insertion bridge, solid max.	95 mm²
Cross section with insertion bridge, stranded max.	70 mm <sup>2</sup>
Cross section with insertion bridge, solid max.	95 mm²
Cross section with insertion bridge, stranded max.	70 mm²
Stripping length	40 mm

## Classifications

## eCl@ss

eCl@ss 4.0	27141118
eCl@ss 4.1	27141118
eCl@ss 5.0	27141118
eCl@ss 5.1	27141141
eCl@ss 6.0	27141141
eCl@ss 7.0	27141141
eCl@ss 8.0	27141141

#### **ETIM**

ETIM 3.0	EC000901
ETIM 4.0	EC000901
ETIM 5.0	EC000901

## **UNSPSC**

UNSPSC 6.01	30211811



## Classifications

#### UNSPSC

UNSPSC 7.0901	39121410
UNSPSC 11	39121410
UNSPSC 12.01	39121410
UNSPSC 13.2	39121410

# Approvals

Α	n	n	rr	١,	2	ıc

Approvals

UL Recognized / cUL Recognized / EAC / cULus Recognized

Ex Approvals

IECEx / ATEX / EAC Ex

Approvals submitted

## Approval details

UL Recognized <b>\$\)</b>	
mm²/AWG/kcmil	4-4/0
Nominal voltage UN	1000 V

cUL Recognized		
	С	
mm²/AWG/kcmil	4-4/0	
Nominal voltage UN	1000 V	

EAC		



# Approvals

cULus Recognized CSUs

## Drawings

Circuit diagram



Phoenix Contact 2015 © - all rights reserved http://www.phoenixcontact.com